

2015 ADA WALKABILITY STUDY - PROJECT STATUS

Study #	Classification	Location	Notes	City Notes on Status	Map Status	Estimated Cost
1	Important, Not Urgent	Aston between Coxe and Church looking west	Tight sidewalk between curb and wall - Unnavigable by wheel chair	Utilities will have to be moved	Current/Future	
2	Urgent/Dangerous	S Lexington near 51 Parking garage and Aloft Hotel looking north	cables, gravel, and trash blocking sidewalk	Letter sent to property owner to clean sidewalk	Current/Future	
3	Urgent/Dangerous	S Lexington at Aston looking south	sidewalk non-existent and in need of replacement	Transportation for new linkage	Current/Future	
4	Urgent/Dangerous	Church at David Gantt's office	very steep slope on sidewalk	Work order (WO) created for driveway portion	Current/Future	\$10,000
5	Important, Not Urgent	Hillard at Church Street	sidewalk ends at parking lot. Also no pedestrian signals at intersection	Plans being drawn to for property - pending easement agreement	Current/Future	\$25,000
6	Urgent/Dangerous	Buxton and Collier	no curb cuts at curb and no crosswalk to designate crossing	Completed	Completed	
7	Urgent/Dangerous	Buxton near the "Prospect" looking west	Major curb blocking sidewalk-unnavigable by wheel chair	Completed	Completed	
8	Urgent/Dangerous	Buxton - near Eno and Prospect	out of grade steep slopes at driveway - out of compliance	WO created, owner does not want drive blocked - coordination needed	Current/Future	\$10,000
9	Urgent/Dangerous	Eno - across the street from Green Man entrance	sidewalk repair needed to fill hole and bump	Completed	Completed	
10	Important, Not Urgent	Millard from Buxton	Over grown vegetation on sidewalk	Letter sent to property owner	Current/Future	
11	Urgent/Dangerous	Buxton at Millard looking east	sidewalk ends into abandoned loading ramp and no sidewalk on the other side	Building intruding to curb - would require narrowed road	Current/Future	\$25,000
12	Urgent/Dangerous	Buxton at Millard	no lip on curb nor crossign marks viable	Completed	Completed	
13	Urgent/Dangerous	Lexington at Buxton	no curb cut, pole blocking sidewalk	Completed by contractor	Completed	
14	Urgent/Dangerous	Southside Ave	sidewalks broken and in need of repair. metal plate over a section	Completed	Completed	
15	Important, Not Urgent	Coxe Avenue at Southside	no pedestrian markings at all. Some corners without ramps or detection for bline. Extremely wide intersection for crossing, possible location for roundabout?	DOT intersection. New development to repair.	Current/Future	
16	Important, Not Urgent	Coxe Avenue	sidwalk lights not functioning - safety	Transportation	Current/Future	
17	Important, Not Urgent	Coxe Ave at Funkatorium	needs curb on sidewalk	Completed	Completed	
18	Urgent/Dangerous	Coxe and Hilliard looking east	not enough space between light pole and building to maneuver. Heavy pedestrian area and needs crossing signals	Utilities need to be moved - requires major new development	Current/Future	
19	Urgent/Dangerous	Coxe at Aston	Sidewalk needs repair, block of concrete - trip hazard and intersection needs detectable warning for blind at crosswalk	WO created	Current/Future	\$8,000
20	Urgent/Dangerous	39 College	loose brick is a stumbling issue hear and all of Lexington - needs mortar	On going maintenance	Current/Future	
21	Urgent/Dangerous	Broadway at Tingle Alley facing South	uneven pavement all the way across alley up to Walnut - difficult for a wheel chair	Contract to repair	Current/Future	
22	Urgent/Dangerous	Alternative Clinic store	no way for wheel chair to enter business - note handicap door operator button	Property owner responsibility	Current/Future	\$0
23	Urgent/Dangerous	Broadway by Finkelsteins	roots raising sidewalk - uneven pavement	WO created	Current/Future	\$15,000
24	Urgent/Dangerous	General issue - construction crews leaving sidewalk obstructions		Contractor spoken to by inspector	Completed	\$0
25	Urgent/Dangerous	Broadway (Market) north of College	sidewalk crumbling and very uneven with old meter pole jutting out	WO created	Current/Future	\$15,000
26	Urgent/Dangerous	Woodfin near Woofin Apts	roots from tree raised sideawk unevenly	WO created	Current/Future	\$10,000
27	Urgent/Dangerous	College St by Van Winkle Parking Lot	tree roots lifting sidewalk	WO created	Current/Future	\$30,000
28	Urgent/Dangerous	College St by K Lounge	crubling sidewalk	WO created	Current/Future	\$10,000
29	Urgent/Dangerous	Eagle St sidewalk, north side	cement lifting in several parts on ramp and no tree grate	Property adjacent to sidewalk	Current/Future	
30	Urgent/Dangerous	Eagle St sidewalk, north side	a brick missing and old sign post jutting out in middle of brick	Completed	Completed	
31	Urgent/Dangerous	Biltmore in front of Barleys	Electrical cover lid is broken and a hazard to pedestrians	Completed	Current/Future	
32	Important, Not Urgent	Biltmore at American Folk	trash cans and newspaper boxes too close to ramp - inhibits passage	Public space/free speech issue to be resolved	Current/Future	
33	Urgent/Dangerous	Ramp at Biltmore & Sycamore	missing bricks near manhole in center of ramp	Completed	Completed	
34	Urgent/Dangerous	Patton Avenue at Lexington	no curb cut at crosswalk and steep ramp to get to sidewalk	Completed	Completed	
35	Urgent/Dangerous	Patton Avenue between Church and Lexington	Sidewalk is not level - trip hazard - note paint	WO created	Current/Future	
36	Urgent/Dangerous	Haywood St	need curb cut on sidewalk	Bond will address	Current/Future	

37	Urgent/Dangerous	Lexington Avenue - all up and down	loose bricks on sidewalk - need to be secured	On going maintenance	Current/Future	
38	Urgent/Dangerous	Church at Commerce looking west	brick crosswalks are difficult to see and maneuver	Transportation - planned	Current/Future	
39	Urgent/Dangerous	Banks and Church	sidewalk ends and there is no crosswalk and no striping	New development to address	Current/Future	
40	Urgent/Dangerous	Transit Center - Coxe and Ashland (Aston)	12% grade - too steep, nad crosswalk leads to curb bump	WO created	Current/Future	
41	Urgent/Dangerous	Commerce & Coxe	no marked crosswalk	County may be addressing, if not, the City will	Current/Future	\$500
42	Urgent/Dangerous	Temporary Crosswalk on Coxe	Leads to bump - needs on/off ramp for wheelchair access	Contractor responsible	Current/Future	
43	Urgent/Dangerous	Coxe & Patton	vehicles moving right on to Coxe from Patton are not effectively yielding to pedestrians, recommend additional signage	In progress (partnership w/ Governor's HWY Safety Improvement Program)	Current/Future	
44	Urgent/Dangerous	College and Market Crosswalk	Crosswalk needs restriping and add curb cuts	Completed	Completed	
45	Urgent/Dangerous	Market St & Walnut	Bricks and asphalt are in disrepair - note the orange cone	Completed	Completed	
46	Urgent/Dangerous	Biltmore at Sycamore	No curb cut at Crossing and no marked crossing at this intersection. Pedestrians dodging traffic	In progress (working with DOT to request additional crossings)	Current/Future	
47	Urgent/Dangerous	Aston/Biltmore	Pothole and major cracks pavement at crosswalk	Completed	Completed	
48	Urgent/Dangerous	Patton Avenue	Loading Zone blocks the crosswalk - relocate the loading zone - extremely wide crosswalk	Completed	Completed	
49	Urgent/Dangerous	Patton Avenue at Coxe Avenue	Need curb cut on crosswalk	Vaulted, property owner responsibility	Current/Future	
50	Urgent/Dangerous	Patton Avenue at Otis	need curb cut on crosswalk	WO created	Current/Future	
51	Urgent/Dangerous	Patton Avenue at French Broad	Need curb cut on crosswalk - corner cut difficult to maneuver for wheel chair	Completed	Completed	
52	Urgent/Dangerous	Haywood St and Montford	Crosswalks are faded and need restriping	Completed	Current/Future	
53	Urgent/Dangerous	Haywood St at O Henry	Crosswalks need curb cuts and restriping	Completed	Completed	
54	Urgent/Dangerous	Lexington Avenue at College	needs curb cut and restriping	Completed	Completed	